

ADDENDUM NO. 1
April 27, 2010
Issued to All Bid Document Holders of Record

Owner: City of Grand Island
Project: **"BID FOR SUBSTATION POWER TRANSFORMERS"**.

This Addendum forms a part of the Contract described above. The original Contract Documents and any prior addenda remain in full force except as modified by the following which shall take precedence over any contrary provisions in the prior documents.

Modify the following:

DETAILED EQUIPMENT SPECIFICATIONS
Page 10G

Existing;
11.0 CABINETS

- A. The control cabinet enclosure shall be stainless steel of the NEMA 4 class. The control cabinet must be conveniently located at an accessible location on tank wall. Weatherproof connections must be used on conduit runs leaving enclosure. Cabinet shall be located so as to be completely interchangeable with existing control cabinet on existing transformer without modification of existing wiring.

Delete;

Cabinet shall be located so as to be completely interchangeable with existing control cabinet on existing transformer without modification of existing wiring.

Dan Schwab
Advantage Engineering, Inc.

ACKNOWLEDGEMENT

The undersigned acknowledges receipt of this Addendum No. 1 and the Bid Submitted is in accordance with information instructions and stipulations set forth herein.

Bidder: _____

By: _____

Date: _____