

ADDENDUM NO. 2

For

Addition to Fire Station Two

CITY OF GRAND ISLAND, NEBRASKA

December 18, 2020

TO: All Bidders on Addition to Fire Station Two

RE: Addendum to modify specification on roof underlayment

The purpose of this Addendum is to clarify:

Replace the specified 30# felt over the roof deck sheathing with two layers of **40 mil. thickness** each of the **self-adhered roofing underlayment Ice & Water Shield (barrier)** over the entire roof of the new addition as manufactured by Grace GCP Applied Technologies. Flash over all rake edges, **bottom roof edges** and lap over the top of slope **of** roof connection to the existing metal **edge** flashing of that **existing** "flat roof" per manufacturer's installation instructions. Refer to Key Note #3 on drawing sheet A4.0 of the WCA Architects.

Acknowledged by _____
Signature of Bidder