

**BOILER INSPECTION AND REPAIR - SPRING 2021 OUTAGE**  
UTILITIES DEPARTMENT – PLATTE GENERATING STATION  
CITY OF GRAND ISLAND, NEBRASKA

***ADDENDUM # 1 TO BID DOCUMENTS***

ISSUE DATE: 2/10/2021

**ADDENDUM:** Additional clarification on sections within the Detailed Specification – Request for Bids

**Detailed Specification – Section 2.0 Scope**

The Owner anticipates that no scaffolding will be used during this outage. All areas will be accessed without the need for scaffolding.

**Detailed Specification – Section 2.2.6 Steam Air Heater**

The Contractor shall inspect all of the coils for leaks and debris on the exterior finned surfaces. The Owner has the blank-off plates if needed.

**Detailed Specification – Section 2.3.3 Boiler Refractory**

Please provide an attachment to your bid with prices for each specific refractory. This price quote shall include the type and quantity for each type of refractory.

**Detailed Specification – Section 3.3 Inspection and Repair**

The bid shall include a lump sum T&M based on working 10 hours per day, based on working six (6) days per week.

Said Addendum #1 is hereby incorporated into the Boiler Inspection and Repair-Spring 2021 Outage bid specification.

***Please acknowledge this Addendum on your BID DATA FORM and CHECKLIST.***