



NOTES:

1. STREET WIDTH USE DEFINED IN SUBDIVISION REGULATION MATRIX
2. ALL SUBGRADE & FILL BELOW PAVEMENT SHALL BE TESTED AND MEET GRAND ISLAND CITY STANDARD SPECIFICATIONS FOR DENSITY AND MOISTURE
3. 12'-0" TRANSVERSE JOINTS
4. CENTERLINE GRADE MINIMUM 0.3%
5. EXPANSION JOINTS LOCATED AT END OF INTERSECTION RETURNS MAXIMUM DISTANCE 500 FEET
6. SIDEWALK LOCATION TO BE LOCATED AS DEFINED IN THE SUBDIVISION AGREEMENT
CURBSIDE SIDEWALK ONLY PERMITTED WHERE NEIGHBORHOOD MAILBOXES ARE PROVIDED
STORM SEWER INLET LID TO MATCH SIDEWALK CROSS SLOPE IF CURBSIDE SIDEWALK INSTALLED
7. PARKING MUST BE RESTRICTED BY DRIVEWAY OPENINGS OR OTHER ITEMS, AND PLAN TO DO SO SHALL BE APPROVED PRIOR TO USE TO ALLOW FOR FIRE DEPARTMENT CLEAR WIDTH REQUIREMENTS. IF PARKING PLAN APPROVAL CAN NOT BE MEET, USE OF 34' PAVING CAN BE SUBSTITUTED WITHOUT PARKING RESTRICTIONS. ADDED WIDTH STREET SHALL MAKE OUTSIDE PANEL 7' ON THE ABOVE DETAIL, OTHERWISE DETAIL REMAINS THE SAME
8. INFORMATION PROVIDED HEREIN REQUIRES USE OF ADDITIONAL CITY STANDARD PLAN DETAILS FOR PROPER CONSTRUCTION



32' RESIDENTIAL STREET STANDARD PAVEMENT CROSS SECTION

CITY STANDARD PLANS & SPECIFICATIONS
GRAND ISLAND, NEBRASKA

PLAN	201		
SHEET	I	OF	I
DRAWN BY:	TJY	DATE:	DEC 2013
REVISED BY:	MLS	DATE:	JAN 2021
APPROVED BY:	KJK	DATE:	JULY 2022