



NOTES:

1. STREET WIDTH USE DEFINED IN SUBDIVISION REGULATION MATRIX
2. ALL SUBGRADE & FILL BELOW PAVEMENT SHALL BE TESTED AND MEET GRAND ISLAND CITY STANDARD SPECIFICATIONS FOR DENSITY AND MOISTURE
3. 12'-0" TRANSVERSE JOINTS
4. CENTERLINE GRADE MINIMUM 0.3%
5. EXPANSION JOINTS LOCATED AT END OF INTERSECTION RETURNS MAXIMUM DISTANCE 500 FEET
6. SIDEWALK LOCATION TO BE LOCATED AS DEFINED IN THE SUBDIVISION AGREEMENT
CURBSIDE SIDEWALK ONLY PERMITTED WHERE NEIGHBORHOOD MAILBOXES ARE PROVIDED
STORM SEWER INLET LID TO MATCH SIDEWALK CROSS SLOPE IF CURBSIDE SIDEWALK INSTALLED
7. PARKING MAY BE RESTRICTED
8. THE DEVELOPER SHALL NOT BE RESPONSIBLE FOR PROVIDING IMPROVEMENTS WIDER THAN 37'-0" AT DEVELOPER'S SOLE EXPENSE
9. INFORMATION PROVIDED HEREIN REQUIRES USE OF ADDITIONAL CITY STANDARD PLAN DETAILS FOR PROPER CONSTRUCTION



41' RESIDENTIAL STREET STANDARD PAVEMENT CROSS SECTION

CITY STANDARD PLANS & SPECIFICATIONS
GRAND ISLAND, NEBRASKA

PLAN	203	
SHEET	I	OF I
DRAWN BY:	TJY	DATE: DEC 2013
REVISED BY:	MLS	DATE: JAN 2021
APPROVED BY:	KJK	DATE: MAR 2021