



CASING DETAIL

CASING SIZE CHART

NOTES:

1. CASING REQUIRED IF WATER MAIN IS LESS THAN 18" FROM SDR CARRIER PIPE. IF GREATER THAN 18" CASING PIPE NOT NEEDED, SEE PLAN I32-A.
2. EXTEND INTO PROPERTY WITH CASING IF REQUIRED TO MEET 10'-0" MINIMUM.
3. 4" MINIMUM SERVICE LINE FOR RESIDENTIAL.
4. 6" MINIMUM SERVICE LINE FOR COMMERCIAL.



SANITARY SEWER SERVICE
WATER CROSSING

CITY STANDARD PLANS & SPECIFICATIONS
GRAND ISLAND, NEBRASKA

PLAN	I32.B	
SHEET	1	OF 1
DRAWN BY:	TJY	DATE: JAN 2013
REVISED BY:	MLS	DATE: MAY 2018
APPROVED BY:	KJK	DATE: JAN 2019