

UTILITIES DEPARTMENT
CITY OF GRAND ISLAND, NEBRASKA

ADDENDUM #1 TO BID DOCUMENTS

FIRE HYDRANT CONTRACT 2012-FH-1

ISSUE DATE: March 21, 2012

ADDENDUM INFORMATION: Modified Caption 200.03 within SECTION 200 --- FIRE HYDRANTS of the Detailed Specifications (see Page E-1 and E-2) as follows:

200.03 FIRE HYDRANTS. Fire hydrants shall conform to the "AWWA STANDARD FOR DRY-BARREL FIRE HYDRANTS," ANSI/AWWA C502 and subsequent revisions. Hydrants shall be manufactured with "O" ring packing, 5-1/4" valve opening, 6" stand pipe, 6" mechanical joint inlet, two 2-1/2" hose connections (nozzle) with 3-1/16" OD and 7-1/2 threads per inch NST and one 4-1/2" pumper connection (nozzle) with 5-3/4" OD and 4 threads per inch NST. Hydrants shall have a 1-1/2" pentagonal operating and nozzle cap nuts which open left or counterclockwise.

Fire hydrants shall be furnished with all the required connecting bolts, nuts, glands, and gaskets.

Fire hydrants shall be painted with an industrial enamel exterior grade paint, with yellow barrels, red caps, and red bonnet. Colors shall be Guardsman Yellow #760-4004-00 and Red #760-7008-00, or Sherwin Williams Yellow #F77Y9 and Red #77R7, or Glidden Yellow #4540 and Red #4520.

Hydrants shall be: American Darling #B-62-B hydrant with five and a half foot bury; or Kennedy Guardian K-81D hydrant with five foot bury; or Mueller Centurion #A-423 3-way hydrant with five foot bury.

INSTRUCTIONS: Please sign below to acknowledge receipt of Addendum #1 to Bid Documents for Fire Hydrant Contract 2012-FH-1. As confirmation of receipt, please return one copy ASAP via fax (or mail if fax is not available) to:

Tom Barnes
Utilities Department
City of Grand Island
P.O. Box 1968
Grand Island, NE 68802-1968

FAX: (308) 385-5449
Phone: (308)-385-5463

Also, please fill in this addendum #1 on your *Bid Proposal* form (see Page C-1) and *Checklist for Bid Submission*.

ACKNOWLEDGEMENT OF RECEIPT OF ADDENDUM:

Received by _____

Company _____ Date _____