

**UTILITIES DEPARTMENT – PLATTE GENERATING STATION
CITY OF GRAND ISLAND, NEBRASKA**

COOLING TOWER RECONDITIONING 2012

ADDENDUM # 1 TO BID DOCUMENTS

ISSUE DATE: July 6, 2012

INSTRUCTIONS: Please sign below to acknowledge receipt of Addendum #1 to Bid Documents for the Cooling Tower Reconditioning 2012 and return. If you prefer, confirmation of receipt of Addendum via email is acceptable.

Karen Nagel
Utility Department, PGS
City of Grand Island
P.O. Box 1968
Grand Island, NE 68802-1968

FAX (308) 385-5353
Phone: (308) 385-5496
knagel@giud.com

ADDENDUM #1:

1. Endwall Louver Seals shall be included in the bid price.
2. Bid prices for the replacement/resealing of the hot water deck shall include the outboard (perimeter) seal only. Lump sum pricing for the replacement/resealing of the inboard seal shall be given as an alternate price.
3. In lieu of neoprene backed washers, involving the louver support arms, industry approved caulking may be used to seal the support hardware.

ACKNOWLEDGMENT OF RECEIPT OF ADDENDUM:

Received by _____
Please Print Signature

Company _____ Date _____

Please also acknowledge this addendum number 1 on your BID DATA FORM and CHECKLIST.