



*Working Together for a  
Better Tomorrow, Today.*

**UTILITIES DEPARTMENT – PLATTE GENERATING STATION  
CITY OF GRAND ISLAND, NEBRASKA**

**CIRCULATION WATER PUMP REPAIR  
ADDENDUM # 1 to Detailed Specifications**

**ISSUE DATE:** October 15, 2012

**INSTRUCTIONS:** Please sign below to acknowledge receipt of Addendum #1 to Detailed Specifications for the Circ Water Pump Repair and return. If you prefer, confirmation of receipt of Addendum via email is acceptable.

Karen Nagel  
Utility Department, PGS  
City of Grand Island  
P.O. Box 1968  
Grand Island, NE 68802-1968

FAX (308) 385-5353  
Phone: (308) 385-5496  
[knagel@giud.com](mailto:knagel@giud.com)

**ADDENDUM #1:  
Page 11 of 37:**

**Additional Items Added:**

Equipment shall be painted to match existing with an industrial coating made to withstand temperatures that would be seen during normal operations.

The elbow of the pump shall be repaired to have adequate thickness to support new stuffing box and interior recoated with a method to prevent further deterioration of from water flowing through the pump.

Method of repair must be specified in the bid documents along with any interior coating. Interior coating specs will be included with the bid documents.

**ACKNOWLEDGMENT OF RECEIPT OF ADDENDUM:**

Received by \_\_\_\_\_  
Please Print Signature

Company \_\_\_\_\_ Date \_\_\_\_\_

***Please also acknowledge this addendum number 1 on your BID DATA FORM and CHECKLIST.***