

**UTILITIES DEPARTMENT – PLATTE GENERATING STATION
CITY OF GRAND ISLAND, NEBRASKA**

PRECIPITATOR, CONVEYOR #4 AND BERM PAINTING 2013

ADDENDUM # 1 TO BID DOCUMENTS

ISSUE DATE: March 7, 2013

INSTRUCTIONS: Please sign below to acknowledge receipt of Addendum #1 to Bid Documents for the 'Precipitator, Conveyor #4 and Berm Painting 2013' and return. If you prefer, confirmation of receipt of Addendum via email is acceptable.

Karen Nagel
Utility Department, PGS
City of Grand Island
P.O. Box 1968
Grand Island, NE 68802-1968

FAX (308) 385-5353
Phone: (308) 385-5496
knagel@giud.com

ADDENDUM #1:

1. An alternative reinforcement product to fiberglass will be allowed if the product can be shown to have attributes equal to or greater than those of a fiberglass reinforcement. These attributes include (but are not limited to) strength, longevity, history of use in sulfuric acid containment, and resiliency. The City of Grand Island reserves the right to decide if alternative product is acceptable based on product information included with the bid.
2. Sheet 13 (Item No. 3 under Diesel Fuel Berm) – Omit the word acid from 'diesel fuel acid berm'.
3. The diesel fuel tank is 4'-0" in length.
4. Alternative pricing shall be provided for any additional, more advanced, surface preparation techniques that may be required beyond those listed in the specification.

ACKNOWLEDGMENT OF RECEIPT OF ADDENDUM:

Received by _____
Please Print Signature

Company _____ Date _____

Please also acknowledge this Addendum number 1 on your BID DATA FORM and CHECKLIST.