

**UTILITIES DEPARTMENT – PLATTE GENERATING STATION
CITY OF GRAND ISLAND, NEBRASKA**

FEEDWATER HEATER #5 INSTALLATION

ADDENDUM # 1 TO BID DOCUMENTS

ISSUE DATE: March 14, 2013

INSTRUCTIONS: Please sign below to acknowledge receipt of Addendum #1 to Bid Documents for the Feedwater Heater #5 Installation and return. If you prefer, confirmation of receipt of Addendum via email is acceptable.

Karen Nagel
Utility Department, PGS
City of Grand Island
P.O. Box 1968
Grand Island, NE 68802-1968

FAX (308) 385-5353
Phone: (308) 385-5496
knagel@giud.com

ADDENDUM #1:

1. All new and replaced insulation, on Feedwater Heater #5 and associated piping, shall have a stucco embossed galvanized aluminum jacketing protective cover in accordance with ASTM B209.
2. Channels of existing heater shall be drained to track bay or approved alternate area upon removal. If water is released on generator floor, Contractor must provide a plan to direct it away from Generator/Turbine and other equipment.

ACKNOWLEDGMENT OF RECEIPT OF ADDENDUM:

Received by _____
Please Print Signature

Company _____ Date _____

Please also acknowledge this addendum number 1 on your BID DATA FORM and CHECKLIST.