

UTILITIES DEPARTMENT – PLATTE GENERATING STATION
CITY OF GRAND ISLAND, NEBRASKA

FEEDWATER HEATER #5 INSTALLATION

ADDENDUM # 2 TO BID DOCUMENTS

ISSUE DATE: March 20, 2013

INSTRUCTIONS: Please sign below to acknowledge receipt of Addendum #2 to Bid Documents for the Feedwater Heater #5 Installation and include with bid package.

Karen Nagel
Utility Department, PGS
City of Grand Island
P.O. Box 1968
Grand Island, NE 68802-1968

FAX (308) 385-5353
Phone: (308) 385-5496
knagel@giud.com

ADDENDUM #2:

1. All aluminum jacketing shall have a thickness of 0.04”.

ACKNOWLEDGMENT OF RECEIPT OF ADDENDUM:

Received by _____
Please Print Signature

Company _____ Date _____

Please also acknowledge this addendum number 2 on your BID DATA FORM and CHECKLIST.