

UTILITIES DEPARTMENT – PLATTE GENERATING STATION  
CITY OF GRAND ISLAND, NEBRASKA

**FIRE ENCLOSURE & CONTROL ROOM ROOF REPLACEMENTS 2013**  
**ADDENDUM # 1 TO BID DOCUMENTS**

**ISSUE DATE:** May 22, 2013

**INSTRUCTIONS:** Please sign below to acknowledge receipt of Addendum #1 to Bid Documents for the 'Fire Enclosure & Control Room Roof Replacements 2013' and return. If you prefer, confirmation of receipt of Addendum via email is acceptable.

Karen Nagel  
Utility Department, PGS  
City of Grand Island  
P.O. Box 1968  
Grand Island, NE 68802-1968

FAX (308) 385-5353  
Phone: (308) 385-5496  
[knagel@giud.com](mailto:knagel@giud.com)

**ADDENDUM #1:**

1. The Control Room roof shall be a 90 mil non-reinforced EPDM.
2. The Fire Enclosure Roof may be a non-reinforced product.

**ACKNOWLEDGMENT OF RECEIPT OF ADDENDUM:**

Received by \_\_\_\_\_  
Please Print Signature

Company \_\_\_\_\_ Date \_\_\_\_\_

***Please also acknowledge this addendum number 1 on your BID DATA FORM and CHECKLIST.***