



*Working Together for a  
Better Tomorrow, Today.*

DATE: July 26, 2013

NUMBER OF PAGES MAILED: 1

FAXED DOCUMENT TO:

SENDER: Todd McCoy, Parks & Recreation Director  
Parks & Recreation Dept., City of Grand Island, Nebraska  
SENDER'S FAX: (308) 385-5488  
Secretary's E-MAIL: pbuettner@grand-island.com

SUBJECT: Addendum No. 1 - Clarification of the wall heater for Stolley Park Restrooms

**ADDENDUM INFORMATION:**

1. Clarification on page E1.1 of the Electrical Specification Drawing. There is no WATER heater. Spec plans show electric WALL heater EWH-1 shall be a 2.0 KW heater, "INDEECO" model #WAI-933UO3000VB-D.

The function of the wall heater is to keep pipes from freezing during cold seasons.

2. To obtain specification material pricing one known Supplier for the concrete block vents and the ceiling vents for air circulation is AIRCAD in Omaha, NE. Matt Bordenkecher at 402-932-1220. Other suppliers of materials or approved equal will also qualify.

Reminder: Bid due date is Wednesday, July 31, 2013 at 2:00 pm local time.

**INSTRUCTIONS:**

Please sign this page as acknowledgement of addendum receipt and return ASAP to the Parks & Recreation Department via fax, e-mail or mail. **Please fill in this addendum number on Contractor's Bid Form.**

Attn: Todd McCoy  
Parks & Recreation Director  
P. O. Box 1968  
Grand Island, NE 68802-1968  
(308) 385-5444 ext,  
FAX (308) 385-5488

**ACKNOWLEDGEMENT OF RECEIPT OF ADDENDUM #1:**

Received by \_\_\_\_\_

Company \_\_\_\_\_

Date \_\_\_\_\_